

WATER

DISINFECTION OF INDIVIDUAL WATER WELLS

A water well should be disinfected (1) when the well is newly drilled; (2) when repairs to the well or pumping equipment are completed; (3) when an unsafe sample has been reported or (4) after a disaster situation which has impacted your home or business. Ordinary liquid laundry bleach may be used to disinfect a well. Liquid laundry bleach contains 5.25 percent chlorine. Care should be taken to avoid using scented bleach as this will contaminate the well.

In order to disinfect a well:

1. Pump the well enough in advance to completely remove sediment and other debris caused by construction or repairs.
2. Add enough chlorine to make 50 to 100 parts per million solution (use table below).
3. Circulate the solution by pumping the discharge back into the well. This can be done by inserting a garden hose through the well seal at the top of the well and pumping until the chlorine is thoroughly mixed (at least fifteen minutes).
4. Open each water tap in the system until a strong chlorine odor is present, then close the tap. This will also disinfect the house service lines.
5. Let the chlorine stand for at least 24 hours, if possible, but no less than two hours.
6. Flush the system thoroughly.
7. Resample after a one week period to allow for the possibility of bacterial regrowth.

If a sample has tested positive, the disinfection has been done and another sample is collected for testing, please write **'RETAKE'** in the Samplers Remarks.

The volume of laundry bleach needed to make a 50 parts per million (ppm) solution may be found from the table below if one knows the depth of the water in the well and the casing (pipe) size. This volume may be doubled to achieve a 100 ppm solution if desired. Further assistance regarding disinfection of your well may be obtained from your local environmental specialist. Questions about the testing can be answered at the **State Environmental Lab (405) 702-1000**.

Amount of Chlorine Bleach Needed				
	Well Diameter			
Depth of Well	3 in.	6 in.	9 in.	12 in.
50 ft.	3 oz.	8 oz.	25 oz.	50 oz.
100 ft.	6 oz.	20 oz.	50 oz.	100 oz.
150 ft.	8 oz.	30 oz.	75 oz.	150 oz.
8 oz. = 1 cup	25 oz. = 3 cups	50 oz. = 6 ^{1/4} cups	100 oz. = 12 ^{1/2} cups	150 oz. = 19 cups, 1 ^{1/4} gals.